

TUNA[®] Sprinklers



Concealed Pendent Series

Model: NX007/ NX008

Standard Spray, Standard Response & Quick Response,
5mm & 3mm Bulb Type, K5.6, 1/2" Connecting Thread

UL approved TUNA[®] glass bulb type, standard spray sprinklers are designed for use in fire sprinkler systems and for use in various commercial applications.


Concealed Pendent Sprinklers NX007 - standard response & NX008 - quick response model series are available with a variety of temperature ratings to meet different design requirements.

Model Types

NX007 Standard Response & NX008 Quick Response



Specification



- 1 Frame; 2 Mounting Cup; 3 Button;
- 4 Spring Seal; 5 Glass Bulb; 6 Enclosure;
- 7 Set Screw; 8 Deflector; 9 Cover Plate;
- 10 Ejection Spring; 11 Label

Model	NX007	NX008
Style	Concealed Pendent Sprinkler	
Bulb Nominal Dia. & Response	Ø5mm, Standard Response	Ø3mm, Quick Response
Thread Size	□NPT1/2 or □R1/2	
Nominal Orifice Size	1/2 Inch	
Nominal K-Factor	5.6 (U.S.) / 80 (metric)	
Max. Working Pressure	175 psig / 1.2 MPa (12 bar)	
Sprinkler Finish	Chrome Plated	
Cover Plate Finish	Painted White	
Nominal Temp. Rating	□ 135°F/57°C or □ 155°F/68°C or □ 175°F/79°C or □ 200°F/93°C	
Max. Ambient Temp.	135°F, 155°F: 100°F (38°C) 175°F, 200°F: 150°F (65°C)	
Listings and Approvals	UL	

Sprinklers, Automatic and Open

COMPANY

Nanjing TUNA Fire Protection Co Ltd

599 ZHUSHAN RD

JIANGNING DISTRICT

NANJING, Jiangsu 211112 China

EX6430

Trademark and/or Tradename: **TUNA**

Note: For additional marking information, refer to the [Guide Information Page](#).

View model for additional information

Glass Bulb Type, SIN(s): [NX001](#), [NX002](#), [NX003](#), [NX004](#), [NX005](#), [NX006](#), [NX007](#), [NX008](#), [NX017](#), [NX018](#), [NX021](#), [NX022](#), [NX023](#), [NX024](#), [NX025](#), [NX026](#)

Last Updated on 2024-05-20

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."